Certificate



No. z2914a-12-E

Customer:

EFB – Elektronik GmbH Striegauer Strasse 1 D-33719 Bielefeld

Test sample(s):

Connector:

INFRALAN® OC45 Keystone Class E_A

Part No.: E-20070

Data Cable:

INFRALAN® Cat.7 Data Cable S/FTP 1000MHz 4x2xAWG23/1

Part No.: 99980.x

Applied standard(s):

ISO/IEC 11801 AMD 2 (2010-04)

Results:

Up to a bandwidth of 500 MHz the sample meet the Class E_A limits of the specified standards and regulations.

2-Connector Permanent Link, Class EA

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. P2914a-12-E, dated April 27th, 2012 and shall only be applicable in conjunction with the test report.

Bexbach, April 27th, 2012

Dirk Wilhelm, engineer (Chairman of the Managing Board)

A CHING 13. 68 0 Box 69 20 CK.

Deutscher Akkreditierungs Rat

GHMT AG In der Kolling 13 D-66450 Bexbach

Phone: +49 (0) 68 26 / 92 28 – 0 Fax: +49 (0) 68 26 / 92 28 – 99 Email: info@ghmt.de